

IEC**IECEE**

®

TM

Ref. Certif. No.

CN55221

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

SWITCH DISCONNECTOR FUSE

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp: 12kV; Ui: 1000V; Ith:800A,1250A.Ue:415V Ie: 800A 1250A; Utilization category:
AC-23B; Number of poles: 3P,4P, 3P+Additional neutral pole(N)(3 protected poles with an
uninterrupted neutral pole); Iq: 100kA; Rated frequency :50/60Hz

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

FUSERBLOC 800A, FUSERBLOC 1250A

Additional information (if necessary may also be reported on page 2)

IEC 60947-3:2020 in conjunction with IEC 60947-1:2020

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099773

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Nov.16,2021

Signature:

谢肇煦

Xie ZhaoXu

CB 0065396