CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010302875907 **Valid from:** Nov.23,2020

Valid until: Jul.20,2031

NAME AND REGISTERED SOCOMEC China Co.,Ltd.

ADDRESS OF THE APPLICANT Unit k, 6/F, No.258, Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED SOCOMEC

ADDRESS OF THE 1, Rue De Westhouse 67230 Benfeld Cedex France
MANUFACTURER

NAME AND LOCATION SOCOMEC S.A

OF THE FACTORY 1, Rue De Westhouse 67230 Benfeld Cedex France

PRODUCT NAME, MODEL Isolator switch

AND SPECIFICATION SIRCO 2000A, SIRCO 2500A, SIRCO 3200A; Uimp:12kV; Ui : 1000V ; Ith : 2000A(SIRCO 2000A), 2500A(SIRCO 2500A), 3200A(SIRCO 3200A) ; Ue : 415V ; Ie : 2000A(SIRCO 2000A), 2500A(SIRCO 2500A), 2

2500A), 3200A(SIRCO 3200A); Icw: 50kA/1s; Ulitization Category: AC-20B; Poles: 6P, 8P;

THE STANDARDS AND GB/T 14048.3-2017 TECHNICAL REQUIREMENTS

FOR THE PRODUCTS

TYPE OF CERTIFICATION SCHEMES

TFICATION Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Apr.10,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

SIGNATURE TO

Tel: +86 10 83886666

