

Certificate of Compliance

Certificate: 1337182

Master Contract: 189705 (112964)

Project: 70107187

Date Issued: 2017-09-11

Issued to: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, 67235
FRANCE

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Patrick Quinty*
Patrick Quinty

PRODUCTS

CLASS - C465102 - SWITCHES-Dead-front (Open Type)

Fused load break switches and non-fused load break switches, open type, for use in industrial control equipment. Certified as disconnecting switches.

Direct operation mechanism, 3 or 4 pole.

Part A: Non-fusible switches, Series SIRCO 400 A and 600A, followed by suffixes, 600V ac max, 250V dc max., rated 200kA at 600V ac and 100kA at 250V dc.

Reference	Cat. No. 3 pole	4 pole
SIRCO 400A	27003040	27004040
SIRCO V 400A, modular design, visible contact	27053039	27054039
SIRCO 600A	27003060	27004060

Part B: Non-fusible switches, Series SIRCO 800 A, 1000 A and 1200 A, 600V ac max.

Reference	Cat. No. 3 pole	4 pole
SIRCO 800A	27003080	27004080
SIRCO 1000A	27003100	27004100
SIRCO 1200A	27003120	27004120



Certificate: 1337182
Project: 70107187

Master Contract: 189705
Date Issued: 2017-09-11

Part C: Fusible switches, Series FUSERBLOC J 600 A and L 800 A, 600V ac max., rated 200kA at 600V ac.

Reference	Cat. No. 3 pole	4 pole	2 pole
FUSERBLOC J 600A	37123060	37126060	
FUSERBLOC L 800A	37123080	37126080	

Fusible switches, Series FUSERBLOC J 600 A and L 800 A, 600V ac max., rated 200kA at 600V ac and 100kA at 250V dc and 10kA 600V dc max.

Reference	Cat. No. 3 pole	4 pole	2 pole
FUSERBLOC J 600A	38503060	38506060	38502060
FUSERBLOC L 800A	38503080	38506080	38502080

Part D: Fusible switches, Series FUSERBLOC J 400 A, 600V ac max, 250V dc max., rated 200kA at 600V ac and 100kA at 250V dc.

Reference	Cat. No. 3 pole	4 pole
FUSERBLOC J 400A	37163040	37166040
FUSERBLOC J 400A without test position	-----	-----

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 4-16 - Enclosed Switches



Supplement to Certificate of Compliance

Certificate: 1337182

Master Contract: 189705 (112964)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70107187	2017-09-11	Update report as per Notice 17 and 21 (CSA C22.2 No.4-16).
2676041	2014-01-21	Modification of short-circuit rating of 250Vdc at 100kA.
2460089	2011-10-19	Addition of alternate plastic: LA70K by BADA, A3K and A3X2G5 by BASF.
2067207	2008-10-22	Add alternate plastic material and change current ratings at 240Vac.
1902886	2007-04-26	CSA report 1337182 update to add modifications
1825996	2007-03-15	CSA file 1337182 update to add new models and alternative plastic materials
1699247	2005-09-27	CSA file update, Model Sirco/Fuserbloc.
1521911	2004-05-14	CSA report 1337182 update - fused load break switches and non-fused load break switches.
History		
1413889	2003-06-05	Report update and corrections. No new models added.
1337182	2002-06-25	Original Certification.