IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

SOCOMEC S.A.S

Name and address of the applicant

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMEC S.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMEC ELECTRIC (SHANGHAI) CO.,LTD A30.NO.5399 Waiqingsong Road, Qingpu Industrial

Park, Shanghai City

☑ Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark (if any)

SOCOMEC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

INOSYS LBS 400A, INOSYS LBS 500A, INOSYS LBS 630A;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN55586, dated 2021-12-21. The issuance of the M1 certificate is to change parameters.

A sample of the product was tested and found

to be in conformity with

IEC 60947-1:2020;IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-099628-M1

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Jan.15,2025 Date:







Name of the factory	Address of the factory
SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
	NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,
	Tunisia

Additional information (if necessary)

Date: Jan.15,2025 Signature:

Tel: +86-10-83886666

Fax: +86-10-83886282

Xie ZhaoXu



INOSYS LBS 400A, INOSYS LBS 500A, INOSYS LBS 630A

Ui:1500V;Uimp:12kV;

INOSYS LBS 400A:

Ith:400A;

2P appearance,4P appearance:DC-21B:Ue/le:DC1000V/400A;

3P appearance:DC-21B,DC-PV2:Ue/le:DC1500V/400A;

2P appearance; DC-21B, DC-PV2: Ue/le: DC1500V/400A;

INOSYS LBS 500A:

Ith:500A;

2P appearance, 3P appearance, 4P appearance: DC-21B, DC-PV2: Ue/le: DC1500V/500A;

INOSYS LBS 630A:

Ith:630A;

2P appearance; 4P appearance: DC-21B: Ue/le: DC1000V/630A;


3P appearance:DC-21B,DC-PV2:Ue/le:DC1500V/630A;


2P appearance; DC-21B, DC-PV2: Ue/le: DC1500V/630A;

Icw:10kA/50ms;Icm:10kA;

DC diagram:

2P appearance(400A/630A):





Signature:

Tel: +86-10-83886666

Fax: +86-10-83886282

Page 1 of 3

Additional information (if necessary)

Date:


Jan.15,2025

谢肇煦


Xie ZhaoXu



2P appearance(400A/500A/630A):



3P appearance(400A/500A/630A):



Page 2 of 3

Additional information (if necessary)

Date:

Jan.15,2025


Xie ZhaoXu

Signature:



4P appearance(400A/500A/630A):

Configuration N°1:2 回路(2 circuits)



Page 3 of 3

Additional information (if necessary)

Date:

Jan.15,2025



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282