



中国国家强制性产品认证证书

证书编号：2025010308805044

认证委托人名称及地址

法国溯高美电气公司

1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

生产者名称及地址

法国溯高美电气公司

1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

生产企业名称及地址

东莞市艾德乐电器有限公司

广东省东莞市寮步镇横中一路 11 号

产品名称和系列、型号、规格

半导体设备保护用熔断体

FP ESS 61Ex3xxx; Un: DC1500V; In: 315A、350A、400A、450A、500A、
550A、630A、700A、800A、900A、1000A、1100A、1200A; 额定分断能力 I1:
250kA; 分断范围和使用类别: aR。 型号解释见附页

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2025 年 08 月 22 日 有效期至: 2029 年 10 月 14 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2025010308805044

证书附页: 第 1 页 共 1 页

型号的解释:

FPESS 61E x 3 xxx

(1) (2) (3) (4) (5)

(1) 产品型号

(2) 产品系列号

(3) 安装方式: 1: DB; 2: UB; 3: FL;

(4) 管号

(5) 电流: 032: 315A; 035: 350A; 040: 400A; 045: 450A; 050: 500A; 055: 550A;
063: 630A; 070: 700A; 080: 800A; 090: 900A; 100: 1000A; 110: 1100A;
120: 1200A;

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025010308805044

NAME AND ADDRESS OF THE APPLICANT

SOCOMEK S.A.S

1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

NAME AND ADDRESS OF THE MANUFACTURER

SOCOMEK S.A.S

1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

NAME AND LOCATION OF THE FACTORY

ADLER Elektrotechnik Dongguan Co.,Ltd.

No.11 of Hengzhong 1st road , Liaobu town,Dongguan city,Guangdong Province

PRODUCT NAME,MODEL AND SPECIFICATION

FUSELINK

FP ESS 61Ex3xxx ; Un : DC1500V ; In : 315A、350A、400A、450A、500A、550A、630A、700A、800A、900A、1000A、1100A、1200A ; Rated breaking capacity II: 250kA; Breaking range and usage category: aR.

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Aug.22,2025

Valid until: Oct.14,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2025010308805044

Appendix: Page 1 of 1

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

型号的解釋:

FP ESS 61E x 3 xxx
(1) (2) (3) (4) (5)

(1) 产品型号

(2) 产品系列号

(3) 安装方式: 1: DB; 2: UB; 3: FL;

(4) 管号

(5) 电流: 032: 315A; 035: 350A; 040: 400A; 045: 450A; 050: 500A; 055: 550A;
063: 630A; 070: 700A; 080: 800A; 090: 900A; 100: 1000A; 110: 1100A;
120: 1200A;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.